

DRAFT

# Certificate of Compliance

Certificate: 1428674

Master Contract: 213339

Project: 1428674

Date Issued: April 28, 2003

Issued to: FuelCell Energy, Inc.  
3 Great Pasture Road  
Danbury, CT 06813-1305  
USA

Attention: Mr. Andrew Skok

*The products listed below are eligible to bear the CSA Mark shown with adjacent indicator 'US'*



Issued by: Greg Chirdon

Authorized by: Todd Strothers  
Engineering Service Manager

## PRODUCTS

2725-81 POWER GENERATORS – Fuel Cell Power Systems

| Model Number<br>For use with Natural Gas | Input<br>(scfm) | Power<br>Output<br>(kW) | Trade Name: FuelCell Energy |
|--|-----------------|-------------------------|-----------------------------|
| DFC <sup>®</sup> 300A                    | 32              | 250kW                   |                             |

## APPLICABLE REQUIREMENTS

ANSI Z21.83-1998 Fuel Cell Power Plants

## MARKINGS

All markings and printed instructions are in compliance with the above mentioned requirements. Samples are contained in the main certification report.

The 'US' indicator adjacent to the CSA Mark signifies that the product has been evaluated to the applicable ANSI/UL Standards, for use in the U.S.. This 'US' indicator includes products eligible to bear the 'NRTL' indicator. NRTL, i.e. National Recognized Testing Laboratory, is a designation granted by the U.S. Occupational Safety and Health Administration (OSHA) to laboratories which have been recognized to perform certification to U.S. Standards.